

CITY OF IDALOU

Public Water Supply ID: TX1520001

Consumer Confidence Report

A decorative L-shaped line consisting of a vertical segment on the left and a horizontal segment at the bottom, both in a dark gray color.

2025 CCR

Annual Drinking Water Quality Report

CITY OF IDALOU

Public Water System ID: TX1520001

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year, for the period of January 1 to December 31, 2025. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. (Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (806-892-2531).

For more information regarding this report, contact:

Name: Oscar Rodriguez

Phone: 806-892-2531

The City of Idalou City Council welcomes public participation at its regular meetings. Meetings are held on the second Monday of each month at 5:30 p.m. in the City Council Chambers, located at 301 Main Street, Idalou, Texas 79329. City Council agendas and approved meeting minutes are available on the City's website at <https://idaloutx.com/meetings-and-agendas/>.

Sources of Drinking Water

The City of Idalou's drinking water is supplied by groundwater from the Ogallala Aquifer located in Idalou, Texas.

Our water source(s) and source water assessment information are listed below:

The full assessment may be viewed in person at 301 Main Street, Idalou, Texas 79329, or <https://idaloutx.com/wp-content/uploads/2026/06/TCEQ-SWAP-DSS-City-of-Idalou-Water-Assessment-Information.pdf>.

You may also access the Water Source Assessment by visiting the City's website at www.idaloutx.com and selecting *Departments* → *Public Works* → [TCEQ SWAP-DSS – City of Idalou Water Assessment Information](https://idaloutx.com/wp-content/uploads/2026/06/TCEQ-SWAP-DSS-City-of-Idalou-Water-Assessment-Information.pdf)

Source Name		Type of Water	Report Status	Location
2 - E 6TH / MULBERRY (EAST)	E 6TH / MULBERRY	Ground water	Yes	https://idaloutx.com/wp-content/uploads/2026/06/TCEQ-SWAP-DSS-City-of-Idalou-Water-Assessment-Information.pdf
3 - 7TH / CHESTNUT (CLUB)	7TH / CHESTNUT	Ground water	Yes	https://idaloutx.com/wp-content/uploads/2026/06/TCEQ-SWAP-DSS-City-of-Idalou-Water-Assessment-Information.pdf

4 - W 6TH / HICKORY (WEST)	W 6TH / HICKORY	Ground water	Yes	https://idaloutx.com/wp-content/uploads/2026/06/TCEQ-SWAP-DSS-City-of-Idalou-Water-Assessment-Information.pdf
7 - 501 E 62 / 82 (JOINER)	501 E 62 / 82	Ground water	Yes	https://idaloutx.com/wp-content/uploads/2026/06/TCEQ-SWAP-DSS-City-of-Idalou-Water-Assessment-Information.pdf

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants - which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. CITY OF IDALOU is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American

National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact CITY OF IDALOU at 806-892-2531. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Avg: Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.

RAA: Running Annual Average.

LRAA: Locational Running Annual Average.

mrem: millirems per year (a measure of radiation absorbed by the body).

ppb: micrograms per liter (ug/L) or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water.

picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

na: not applicable.

Disinfectant Residual

All public water systems in Texas are required to disinfect drinking water to ensure control of microbial contaminants. Disinfectants are water additives used to control microbes.

Disinfectant	Year	Average Level	Unit	Range	MRDL/MRDLG Goal
Chlorine	2025	.81/1.66	4	4	4/4

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Lead and Copper	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low - high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2025	0.154	0.00635 - 0.337	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2025	0.948	0 - 1.84	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	103 1ST, IDALOU	2024	7	7.4	ppb	60	0	By-product of drinking water disinfection
TTHM	301 MAIN, IDALOU	2025	6	6.23	ppb	80	0	By-product of drinking water chlorination

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
1,1-DICHLOROETHYLENE	7/28/2025	14.1	0 - 14.1	ppb	7	7	Discharge from industrial chemical factories
ARSENIC	4/29/2025	8.5	6.5 - 8.5	ppb	10	0	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM	4/29/2025	0.082	0.072 - 0.082	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	4/29/2025	2.7	1.5 - 2.7	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits
DIBROMOCHLOROMETHANE	7/28/2025	1.93	0 - 1.93	UG/L	0	0.06	
FLUORIDE	5/28/2024	2.06	2.06	ppm	4	4	Natural deposits; Water additive which promotes strong teeth.
NITRATE	2/13/2025	4.24	2.17 - 4.24	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	2/23/2021	3.47	1.47 - 3.47	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

SELENIUM	4/29/2025	6.9	0 - 6.9	ppb	50	50	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED URANIUM	5/28/2024	13.4	10.8 - 13.4	µg/L	30	0	Erosion of natural deposits
GROSS ALPHA, EXCL. RADON & U	2/26/2024	3	1 - 3	pCi/L	15	0	Erosion of natural deposits
GROSS ALPHA, INCL. RADON & U	2/26/2024	10.4	9.9 - 10.4	pCi/L	0	0	Erosion of natural deposits
Violation Period	5/28/2024	18.6	11.9 - 18.6	pCi/L	50	0	Decay of natural and man-made deposits.
10/17/2024 - 1/9/2025							

Violations

During the period covered by this report we had the below noted violations.

	Analyte	Violation Type	Violation Explanation
	PUBLIC NOTICE	PUBLIC NOTICE RULE LINKED TO VIOLATION	Failed to issue public notice or failed to provide a copy of the notice and certification to the state
10/17/2024 - 1/9/2025	LEAD AND COPPER RULE REVISIONS	LSL INVENTORY-INITIAL	
10/17/2024 - 1/9/2025	LEAD AND COPPER RULE REVISIONS	LSL REPORTING-INITIAL	
1/1/2025 - 6/30/2025	LEAD & COPPER RULE	WATER QUALITY PARAMETER M/R (LCR)	Failed to meet water quality parameter sampling or reporting requirements
1/1/2025 - 3/31/2025	1,1-DICHLOROETHYLENE	MCL, AVERAGE	Average result caused MCL exceedance
4/1/2025 - 6/30/2025	1,1-DICHLOROETHYLENE	MCL, AVERAGE	Average result caused MCL exceedance
7/1/2025 - 9/30/2025	PUBLIC NOTICE	PUBLIC NOTICE RULE LINKED TO VIOLATION	Failed to issue public notice or failed to provide a copy of the notice and certification to the state
7/1/2025	CONSUMER CONFIDENCE RULE	CCR ADEQUACY/AVAILABILITY/CONTENT	Inadequate Consumer Confidence Report (CCR) or failure to deliver a CCR Certification form to the state on time
7/1/2025 - 9/30/2025	1,1-DICHLOROETHYLENE	MCL, AVERAGE	Average result caused MCL exceedance
7/2/2025	LEAD AND COPPER RULE REVISIONS	NOTIFICATION, KNOWN OR POTENTIAL LSL	
9/29/2025	LEAD & COPPER RULE	LEAD CONSUMER NOTICE (LCR)	Failed to meet content, delivery, and/or reporting requirements for lead consumer notification

10/1/2025 - 12/31/2025	PUBLIC NOTICE	PUBLIC NOTICE RULE LINKED TO VIOLATION	Failed to issue public notice or failed to provide a copy of the notice and certification to the state
10/1/2025 - 12/31/2025	1,1-DICHLOROETHYLENE	MCL, AVERAGE	Average result caused MCL exceedance

Corrective Actions

The City of Idalou takes compliance with drinking water regulations seriously and has implemented corrective actions to address the violations listed above.

- The City completed the required Lead Service Line Inventory and submitted the inventory and associated reporting to the Texas Commission on Environmental Quality (TCEQ). The inventory has also been made available for public review on the City's website in accordance with regulatory requirements.
- The City worked with TCEQ to establish a revised Lead and Copper Rule sampling schedule and has implemented procedures to ensure future monitoring is conducted during the required compliance periods. Customer notification procedures have also been updated to ensure all required Lead Consumer Notices and Lead Service Line notifications are completed and documented in accordance with regulatory requirements.
- The City implemented treatment improvements at Entry Point 01 (EP01), one of the City's groundwater sources, which have successfully reduced 1,1-Dichloroethylene concentrations at that entry point. While both Entry Point 01 (EP01) and Entry Point 04 (EP04) contributed to the MCL violations during the reporting period, the improvements at EP01 have effectively addressed the elevated concentrations at that location.
- The City is now working with its engineer to evaluate long-term system improvements to optimize water quality associated with Entry Point 04 (EP04), including modifications to the distribution system to improve water quality throughout the system. The City will continue to monitor water quality and implement appropriate corrective actions to ensure compliance with state and federal drinking water standards.

Additional Required Health Effects Language:

Some people who drink water containing 1,1-dichloroethylene in excess of the MCL over many years could experience problems with their liver.

This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine (9) years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than two (2) milligrams per liter (mg/L) of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis). The drinking water provided by your community water system has a fluoride concentration greater than 2.0 mg/L. Dental fluorosis, in its moderate or severe forms, may result in a brown staining and/or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine (9) should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water. Drinking water containing more than four (4) mg/L of fluoride (the maximum contaminant level for fluoride) can increase your risk of developing bone disease. Your drinking water does not contain more than four (4) mg/L of fluoride, but we are required to notify you when we discover that the fluoride levels in your drinking water exceed two (2) mg/L because of this cosmetic dental problem. For more information, please call at the phone number located under the heading "How might I become actively involved?" on page 1 of this report. Some home water treatment units are also available to remove fluoride from drinking water. To learn more about available home water treatment units, you may call NSF International at 1-877-8-NSF-HELP.

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

There are no additional required health effects violation notices.

SERVICE LINE INVENTORY

A service line inventory has been prepared and is available for public review. The inventory identifies the materials of service lines connected to our public water system. If you would like to know the material of the service line at your property or access the complete inventory, you may visit City Hall at 301 Main Street, Idalou, Texas 79329, call us at (806) 892-2531, or view the inventory online at:

<https://idaloutx.com/wp-content/uploads/2026/07/City-of-Idalou-Lead-Line-Service-Inventory-2025.pdf>

You may also access the inventory by visiting the City's website at www.idaloutx.com and selecting *Departments → Public Works → City of Idalou Lead Line Service Inventory 2025*.

PWS / 1520001 / CO

Mandatory Language for a Maximum Contaminant Level Violation MCL, Average/1,1-DICHLOROETHYLENE

The Texas Commission on Environmental Quality (TCEQ) has notified the **City of Idalou TX1520001** the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for 1,1-DICHLOROETHYLENE. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for 1,1-DICHLOROETHYLENE to be 0.007 milligrams per liter (mg/L) based on a running annual average (RAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for 1,1-DICHLOROETHYLENE indicates a compliance value in **quarter one 2026 of 0.012 mg/L for EP004 quarter two 2026 of 0.012 mg/L for EP004.**

Some people who drink water containing 1,1-DICHLOROETHYLENE in excess of the maximum contaminant level (MCL) over many years could experience problems with their liver.

We are taking the following actions to address this issue:

The City operates four drinking water well sites, each with a separate entry point and individual chemical analysis:

1. Entry Point One (EP001): Near 5th & Hickory
2. Entry Point Two (EP002): Near 7th & Chestnut
3. Entry Point Three (EP003): Near E. 6th Street & Mulberry
4. Entry Point Four (EP004): North of US 62/82 near Wildcat Towing

The City is testing all sites on a monthly basis as a precaution and is working closely with the City Engineer to identify long-term solutions. Options under consideration include blending water from another well site or evaluating whether Entry Point 04 should remain in service.

The City of Idalou remains committed to providing safe, high-quality drinking water and will continue to take corrective actions as needed to comply with state and federal standards.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Contact Information:

Suzette Williams
City Administrator
City of Idalou
Ph: 892-2531
Fax: 892-3298

PWS / 1520001 / CO

Mandatory Language for a Maximum Contaminant Level Violation MCL, Average/1,1-DICHLOROETHYLENE

The Texas Commission on Environmental Quality (TCEQ) has notified the **City of Idalou TX1520001** the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for 1,1-DICHLOROETHYLENE. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for 1,1-DICHLOROETHYLENE to be 0.007 milligrams per liter (mg/L) based on a running annual average (RAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for 1,1-DICHLOROETHYLENE indicates a compliance value in **quarter three 2025 of 0.009 mg/L for EP004 and quarter four 2025 of 0.011 mg/L for EP004.**

Some people who drink water containing 1,1-DICHLOROETHYLENE in excess of the maximum contaminant level (MCL) over many years could experience problems with their liver.

We are taking the following actions to address this issue:

The City operates four drinking water well sites, each with a separate entry point and individual chemical analysis:

1. Entry Point One (EP001): Near 5th & Hickory
2. Entry Point Two (EP002): Near 7th & Chestnut
3. Entry Point Three (EP003): Near E. 6th Street & Mulberry
4. Entry Point Four (EP004): North of US 62/82 near Wildcat Towing

The City is testing all sites on a monthly basis as a precaution and is working closely with the City Engineer to identify long-term solutions. Options under consideration include blending water from another well site or removing the well from service altogether.

The City of Idalou remains committed to providing safe, high-quality drinking water and will continue to take corrective actions as needed to comply with state and federal standards.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Contact Information:

Suzette Williams
City Administrator
City of Idalou
Ph: 892-2531
Fax: 892-3298